

PROVINDING AND LAYING SEWAGE LINE AT CENTRAL LIBRARY AND SAC BUILDING AT					
S.NO.	DESCRIPTION OF ITEMS	QTY	UNIT	QUOTED RATE	QUOTED AMOUNT
1	DSR 2023 ITMES NO.2.10.1.2				
	2.10 Excavating trenches of required width for pipes, cables, etc including excavation for sockets, and dressing of sides, ramming of bottoms, depth upto 1.5 m, including getting out the excavated soil, and then returning the soil as required, in layers not exceeding 20 cm in depth, including consolidating each deposited layer by ramming, watering, etc. and disposing of surplus excavated soil as directed, within a lead of 50 m :				
	2.10.1 All kinds of soil				
	2.10.1.2 Pipes, cables etc. exceeding 80 mm dia. But not exceeding 300 mm dia				
	For Sewage line	30			
	Total Quantity	30	Metre		
2	DSR 2023 ITMES NO.2.10.1.2				
	2.13 Excavating trenches of required width for pipes, cables, etc, including excavation for sockets, depth upto 1.5 m, including getting out the excavated materials, returning the soil as required in layers not exceeding 20 cm in depth, including consolidating each deposited layers by ramming, watering etc., stacking serviceable material for measurements and disposal of unserviceable material as directed, within a lead of 50 m :				
	2.13.1 Ordinary rock :				
	2.10.1.2 Pipes, cables etc. exceeding 80 mm dia. But not exceeding 300 mm dia				
	For Sewage line	20			
	Total Quantity	20	Metre		
3	DSR 2023 ITMES NO.19.7.1.1				
	19.7 Constructing brick masonry manhole in cement mortar 1:4 (1 cement : 4 coarse sand) with R.C.C. top slab with 1:1.5:3 mix (1 cement : 1.5 coarse sand (zone-III) : 3 graded stone aggregate 20mm nominal size), foundation concrete 1:4:8 mix (1 cement : 4 coarse sand (zone-III) : 8 graded stone aggregate 40 mm nominal size), inside plastering 12 mm thick with cement mortar 1:3 (1 cement : 3 coarse sand) finished with floating coat of neat cement and making channels in cement concrete 1:2:4 (1 cement : 2 coarse sand : 4 graded stone aggregate 20 mm nominal size) finished with a floating coat of neat cement complete as per standard design :				
	19.7.1 Inside size 90x80 cm and 45 cm deep including C.I. cover with frame (light duty) 455x610 mm internal dimensions, total weight of cover and frame to be not less than 38 kg (weight of cover 23 kg and weight of frame 15 kg) :				
	19.7.1.1 With common burnt clay F.P.S. (non modular) bricks of class designation 7.5				
	For Sewage line	4			
	Total Quantity	4	Each		
4	DSR 2023 ITMES NO. 19.8.1				
	19.8 Extra for depth for manholes :				

	19.8.1 Size 90x80 cm 19.8.1.1 With common burnt clay F.P.S. (non modular) bricks of class designation 7.5				
	For Sewage line	4			
	Total Quantity	4	Metre		
5	DSR 2023 ITMES NO. 19.21.1				
	19.21 Making connection of drain or sewer line with existing manhole including breaking into and making good the walls, floors with cement concrete 1:2:4 mix (1 cement : 2 coarse sand : 4 graded stone aggregate 20 mm nominal size) cement plastered on both sides with cement mortar 1:3 (1 cement : 3 coarse sand), finished with a floating coat of neat cement and making necessary channels for the drain etc. complete :				
	19.21.1 For pipes 100 to 250 mm diameter	4			
	Total Quantity	4	Each		
6	DSR 2023 ITMES NO. 19.2.2				
	19.2 Providing and laying cement concrete 1:5:10 (1 cement : 5 coarse sand : 10 graded stone aggregate 40 mm nominal size) all-round S.W. pipes including bed concrete as per standard design :				
	19.2.2 150 mm diameter S.W. pipe				
	For Sewage line	50			
	Total Quantity	50	Metre		
	Total Amount				
7	Other Misc. Work as per dsr2023 on % Rate Basis OF 30000/-				
	Total Gross Amount				

Name of sign of Contractor